

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	20.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.15	*****	7.41				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	13.26	21.56		*****	1.53	1.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	125				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.093	.113		*****	8.4	8.8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0012	.0025		*****	.6	.3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.114	.25		*****	9.8	21.7				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.043	.066		*****	3.8	5.7		2		
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.043	.066		*****	3.8	5.7		2		
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.18	2.56		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	0	0				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	25.31	34.59		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	15.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.49	*****	7.63				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.14	4.49		*****	2.3	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	159				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.024	.055		*****	36	64				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0012	.003		*****	0	0				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0143	.0348		*****	14	20				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.027	.063		*****	28	37				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.17	.32		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2012	05/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1570	2845		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.5	*****	7.62				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	15.36	35.89		*****	1.35	2.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	129				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.06306	.1058		*****	5.9	8.3				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00385	.0044		*****	.36	.39				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.10202	.1461		*****	9.5	11.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.05948	.0676		*****	5.6	6.3		2		
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.17	3.17		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	19.848	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.29	*****	7.76				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.1487	6.3438		*****	2.1	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	174				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .05	< .05				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0008	.0009		*****	.4	.4				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0302	.0409		*****	14	18				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0994	.1741		*****	42	73				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.374	.536		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2012	06/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1533.555	2662.187		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	27.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.21	*****	7.47				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	51.20075	184.0896		*****	10.4	18.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	129				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.06477	.1909		*****	6.5	9.5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00045	.0018		*****	0	.19				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07328	.0894		*****	7.6	8.9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.06246	.1547		*****	6.5	15.8		2		
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.85	2.44		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	80				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	5.681	8.12		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.89				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.45	*****	7.89				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.5803	2.3212		*****	1.2	1.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	194				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0141	.0259		*****	1	3				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0382	.0613		*****	3	8				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.322	.46		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2012	07/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	208.828	550.477		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.27	*****	7.56				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.96571	14.8286		*****	1.7	2.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	133				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.003	.015		*****	.3	1.72				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.06442	.1103		*****	6.3	9.1				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.02997	.0612		*****	3	6.6				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.86	2.5		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .00001	< .00001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1.246	2.94		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
TYPED OR PRINTED					AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.89				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.86	*****	8.13				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.4921	2.4606		*****	1.6	1.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	194				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0118	.0274		*****	10	18				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0222	.0468		*****	19	30				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.219	.46		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2012	08/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	87.989	102.751		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.35	*****	7.76				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	< 1	< 1		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	140				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02005	.0802		*****	2.6	10.4				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00099	.0016		*****	.1	.2				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.03854	.019		*****	4.6	6.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.01641	.019		*****	2	2.5				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.7	2.26		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	8				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .00001	< .00001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.646	1.66		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.05	*****	8.34				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	3.8067	15.2251		*****	1.6	1.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	255				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0002	.0003		*****	0	.2				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0157	.0302		*****	10	15				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0199	.0311		*****	15	21				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.21	.46		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2012	09/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	70.701	75.047		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	15.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.23	*****	7.48				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.07133	8.2625		*****	1.3	1.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	133				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.000956	.0382		*****	1.4	5.5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00053	.0021		*****	.1	.3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.03769	.0492		*****	5.7	7				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.02699	.0585		*****	4.2	9.2				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.41	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .00001	< .00001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.0711	2.5		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.94	*****	8.39				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.96656	11.8663		*****	1.9	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	258				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.013	.0342		*****	4	10				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0003	.0011		*****	0	.2				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0729	.2028		*****	20	37				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0664	.0923		*****	28	41				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.515	1.431		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2012	10/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	74.953	104.908		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.71	*****	8.18				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	30.6				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02556	.1278		*****	2.1	10.5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00056	.0017		*****	.1	.18				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.06486	.1173		*****	7.4	12.3				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02775	.052		*****	3.2	6				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.13	4.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	170				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .00001	< .00001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	5.014	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .00001				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	10.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.41	*****	8				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1.45937	7.2449		*****	1	1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	67.2				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0499	.0891		*****	14	20				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.005	.0011		*****	0	.4				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1115	.2208		*****	32	45				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.1185	.2277		*****	35	46				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.517	1.431		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2012	11/30/2012

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5.58				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	118.408	348.027		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.48				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	147				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.07302	.182		*****	6.4	13.5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00035	.0014		*****	.1	.14				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.04416	.1362		*****	3.6	10.1				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0282	.0383		*****	2.7	4.1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.09	3.17		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	50				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	.00001	.00001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	10.34	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.71	*****	8.11				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	218				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.068	.0843		*****	15	18				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0006	.001		*****	0	.3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1306	.1929		*****	29	33				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.2732	.3564		*****	61	70				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.713	9.7		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2012	12/31/2012

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	230.416	1037.38		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.48				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1.0026	5.0129		*****	1.33	1.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	141				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.06132	.0817		*****	7.5	10				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.00026	.001		*****	0	.13				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.03099	.0787		*****	4.8	9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02238	.0304		*****	2.5	3.5				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.65	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	50				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	.00011	.00023		*****	0	.027		1		
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	3.21	4.13		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.68	*****	8.01				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1.6547	8.2733		*****	2.2	2.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	193				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0441	.0515		*****	10	14				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0002	.0006		*****	0	.2				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.124	.1911		*****	29	39				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.4155	.6683		*****	97	135		32		
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.75	1.025		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2013	01/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	96.484	115.392		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.54	*****	8.8				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.94729	23.7892		*****	2.5	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	141				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.05095	.0676		*****	5.3	6.9				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.05095	.0676		*****	5.3	6.9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.04427	.0628		*****	4.4	6.6				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.84	2.14		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	140				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	3.42	4.13		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 8				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
TYPED OR PRINTED					AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.26	*****	8.35				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.6347	12.7596		*****	3	8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	200				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0226	.0468		*****	6	11				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0541	.0661		*****	14	20				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.5085	.6442		*****	130	160				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.727	.885		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2013	02/28/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	88.498	114.846		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.31	*****	7.52				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	6.0958	24.3418		*****	2	2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	120				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.05309	.0718		*****	4.3	5.9				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.08129	.0986		*****	5.8	8.1				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.03347	.0475		*****	2.7	3.8				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.42	4.37		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	900				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	10.842	21.3		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	8.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.07	*****	7.81				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	3.3348	33.1751		*****	7.8	19				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	180				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0258	.0453		*****	8	13				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1235	.3965		*****	38	110		32		
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.2979	.9371		*****	100	260		1		
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.504	1.025		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2013	03/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	202.6	416.643		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI 9	*****	NODI 9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.25381	42.0305		*****	1.75	4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	150				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.05309	.0718		*****	4.3	5.9				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.12398	.4803		*****	6.5	20				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.07996	.3547		*****	3.9	16		32		
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.82	4.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	50				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	18.865	34.59		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI 9	*****	NODI 9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.9314	14.1303		*****	4.7	10				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	180				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0258	.0453		*****	8	13				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .9	< .9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1169	.2708		*****	34	72		30		
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.266	.5265		*****	78	140				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.462	.697		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2013	04/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	774.226	2323.42		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.16	*****	8.02				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	11.53774	69.2264		*****	5.4	14				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .005	< .005				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.08885	.1785		*****	7.2	14				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.01708	.0518		*****	1.8	5.6				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.35	4.63		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	20.469	34.59		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2013	05/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440

WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD

WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

LAKE CREEK

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.9	*****	8.75				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	0	0				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .005	< .005				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.05505	.104		*****	5.2	9.5				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.00876	.035		*****	.8	3.2				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.08	2.5		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	7.507	11.49		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2013	06/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.38	*****	8.77				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1.78899	10.734		*****	.6	1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	140				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.00783	.0392		*****	.8	4				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0364	.0662		*****	2.7	3.9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.09	3.32		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2.816	5.59		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2013	07/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.92	*****	8.71				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.013	.053		*****	1.4	5.6				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.83	2.32		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.95	3.49		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2013	08/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.25				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	.25	1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .5	< 5				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.007	.026		*****	.7	2.7				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.88	2.63		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.709	4.88		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2013	09/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.25				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	.25	1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.007	.026		*****	.7	2.7				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.88	2.63		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.709	4.88		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2013	10/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	102.967	143.779		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	8.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.36	*****	8.21				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	40.82	106.73		*****	4	9				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.04	.06		*****	4.4	5.2				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.18	.3		*****	19.5	28				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.076	.19		*****	7.7	16				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.06	3.17		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	140				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC
ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1.69	6.98		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .0001				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.03	*****	7.53				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	17.48	47.94		*****	12.8	25				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.017	.022		*****	11	16				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.03	.07		*****	20	52				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.09	.07		*****	62	120				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.249	.488		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	88.15	127.46		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	11.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.41	*****	7.73				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	27.78	57.96		*****	3.25	8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.016	.062		*****	2.2	8.6				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.123	.268		*****	13.8	37				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.033	.071		*****	3.5	9.8				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.77	3.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	140				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2.73	5.99		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .0001				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.34	*****	7.64				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.44	29.41		*****	5.5	17				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.02		*****	12	13				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.024	.048		*****	15	28				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.103	.13		*****	60	75				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.304	.359		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .0001	< .0001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	87	137		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	10.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.65	*****	8.64				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	83.26	311.64		*****	5.6	22				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.066	.269		*****	4.4	19				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.21	.74		*****	14.3	52				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.085	.26		*****	5.4	18				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.16	4.46		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1.16	3.94		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.91	*****	8.91				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	10.1	22.56		*****	3.6	7				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	190				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.03	.05		*****	11	15				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.04	.12		*****	16	45				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC
ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.15	.32		*****	56	120				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.46	.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	82	109		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	9.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.51	*****	8.64				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	88	202		*****	6.28	15				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	120				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.04	.11		*****	2.5	5.1				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.15	.45		*****	8.5	21				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.06	.13		*****	3.7	5.9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.6	4.8		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2.146	8.89		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.67	*****	8.01				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	23.32	74.01		*****	3.3	8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	180				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.08	.22		*****	12	24				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.09	.22		*****	15	26				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC
ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.42	.69		*****	87	168				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.79	1.72		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	155	1803		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	7.92				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	25.37	42.11		*****	1.95	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	104				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.12		*****	4.8	8.6				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.03	.04		*****	2.1	2.8				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.74	4.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	18.86	64.37		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	10.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.93	*****	7.6				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	32.29	60.17		*****	5.8	8.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	72.2				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.11	.17		*****	19	23				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.001	.0022		*****	.2	.3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.17	.41		*****	26	60				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.72	1.74		*****	118	256				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.17	1.98		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	571	2897		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.84	*****	7.57				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	7.41	14.83		*****	.55	1.1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	119				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.08		*****	< 5	5.7				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.09	.14		*****	6.7	10				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.04	.05		*****	3	6.7				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.7	3.62		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	19.89	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	12.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.99	*****	7.68				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.95	3.81		*****	.3	1.1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	145				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.01	.03		*****	3	8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.045	.049		*****	12	14				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.066	.086		*****	18	25				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.71	1.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	712	1494		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	21.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.27	*****	8.14				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	26.82	58.82		*****	1.56	3.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	124				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	5.7				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.15	.29		*****	8.3	13.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.04	.06		*****	2.5	3				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.87	3.94		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	28.5	38.13		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	26.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.36	*****	7.9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.27	11.77		*****	1.8	3.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	150				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.005	.019		*****	1	5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.045	.126		*****	21	37				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC
ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.058	.156		*****	28	45				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.277	.64		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1952	2852		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	20.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.49	*****	8.46				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	49	137		*****	3.13	8.02				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	126				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	5.7				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.19	.28		*****	13.1	16.6				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.03	.06		*****	2.4	3.3				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.13	3.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	49				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	12.7	21.3		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	27.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.68	*****	8.18				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	3.94	19.68		*****	.38	1.9				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	135				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.11		*****	6.1	9.8				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	2	2.2				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.9	3.17		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	3.66	6.98		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.7	*****	7.83				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	144				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.13		*****	7.7	12.8				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	2.1	2.7				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.75	2.04		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.91	1.75		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0	0		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	83	91		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	20.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	7.9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	8	21.7		*****	1.03	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	154				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.18	.28		*****	22.9	39.1				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	2.3	4.6				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.51	1.72		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.56	.58		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2014	09/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	15.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.32	*****	7.57				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	3.39	9.26		*****	.44	1.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	155				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.097	.198		*****	12.5	25.6				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.014	.018		*****	1.8	2.3				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.48	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	33				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.59	.9		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	11.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.69	*****	7.99				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	10.15	12.64		*****	3.7	4.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	107				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.03	.03		*****	9	13				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.1		*****	26	30				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.13	.21		*****	52	78				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.29	.7		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	350				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2014	10/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	68	86		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	14.9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.12	*****	7.67				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	8.9	19.07		*****	1.4	3				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	172				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.04	.06		*****	5.7	9.1				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.11	.24		*****	16.2	30.8				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.023	.035		*****	3.6	5.5				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.51	3.94		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	350				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2.29	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE	
TYPED OR PRINTED					AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.68	*****	7.84				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.3	6.32		*****	2.8	4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	107				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.04	.05		*****	18	20				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.05	.09		*****	27	62				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.11	.17		*****	52	67				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.46	.95		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2014	11/30/2014

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	99	617		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	15.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.16	*****	7.43				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	12.8	30.58		*****	.93	1.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	138				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.047	.073		*****	< 5	6.8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.053	.146		*****	5.7	17.8				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.044	.099		*****	3	4.9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.88	3.78		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	540				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	5.12	6.98		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.67	*****	7.66				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	6.33	11.06		*****	2.4	3.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	158				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.049	.06		*****	20	25				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.059	.128		*****	25	54				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.117	.161		*****	46	68				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.41	.64		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2014	12/31/2014

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0			*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	114	132		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.67	*****	7.51				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.65	19.19		*****	1.08	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	164				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.15	.6		*****	16.3	65				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.14	.22		*****	15.9	28.2				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.026	.083		*****	2.8	9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.68	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	6.68	18.65		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.72	*****	7.8				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	8.69	14.22		*****	2.9	4.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	178				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.072	.22		*****	28	63				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.052	.09		*****	19	29				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.066	.098		*****	24	31				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.47	.7		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2015	01/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	6.68	18.65		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.16	*****	7.76				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	18.48	38.99		*****	1.53	2.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	129				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.036	.097		*****	2.9	6.2				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.22	.48		*****	22.2	45.7				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.022	.051		*****	1.9	3.3				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.13	4.63		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	240				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	14.87	41.73		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.9	*****	7.77				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.56	5.23		*****	1.1	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.05		*****	5	10				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.053	.093		*****	18	20				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.035	.059		*****	11	12				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.57	.89		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2015	02/28/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	618	2188		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17.1			Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.42	*****	7.74			Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	10.72	16.42		*****	1.13	1.6			Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	136			Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5			Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3			Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.26	.45		*****	26.3	45.4			Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.013	.025		*****	1.3	2.3			Weekly	COMP24
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.91	3.62		*****	*****	*****	*****		Daily	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	33			Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01			Twice per Month	GRAB
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	13.9	45.46		*****	*****	*****	*****		Daily	Recorder (auto)
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01			Quarterly	COMP24
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	15.2			Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.24	*****	8.8			Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.29	3.84		*****	1.4	2.8			Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	137			Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5			Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3			Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.022	.034		*****	16	20			Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.174	.89		*****	*****	*****	*****		Daily	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0			Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2015	03/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01			Twice per Month	GRAB
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	581	2681		*****	*****	*****	*****		Daily	Recorder (auto)
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.99	*****	7.55				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.21	15.54		*****	.99	1.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	151				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.006	.023		*****	.26	.7				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.22	.47		*****	24.2	45.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.016	.023		*****	1.8	2.6				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.56	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	8.23	19.98		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.13	*****	8.9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.28	7.4		*****	5.9	11				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	136				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.004	.01		*****	3	8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.009	.01		*****	8	15				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.012	.025		*****	13	15				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.13	.3		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2015	04/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	278	869		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.41	*****	7.83				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.84	39.37		*****	1.45	5.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	158				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT				*****						
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1	.14		*****	1.3	1.6				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	2.5	4.9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.56	1.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	79				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2.33	3.94		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	25.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.56	*****	7.56				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.66	18.62		*****	15.5	15.5				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	136				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.006	.006		*****	5	20				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.005	.02		*****	4	17				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.06	.22		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2015	05/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT				*****						
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	169	243		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.33	*****	7.92				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.04	8.15		*****	.3	1.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	151				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.13	.16		*****	17	23.6				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.43	1.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.84	1.42		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.91	*****	7.6				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.05	10.1		*****	3.3	6.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	157				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	17	21				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.03		*****	13	16				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.06	.29		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	79				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2015	06/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	97	141		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	27.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.36	*****	7.79				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.74	12		*****	.8	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	178				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.07		*****	2.2	6.3				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.19	.4		*****	23.6	36.9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.01	.02		*****	1.2	1.8				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.49	2.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	33				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.57	.58		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI 9	*****	NODI 9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2015	07/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	70.2	75.5		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.67	*****	8.07				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.62	10.49		*****	.55	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	162				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.13	.27		*****	23.6	42.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.009	.03		*****	2	5.2				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.97	1.34		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.51	.55		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2015	08/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	19.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.12	*****	7.57				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.39	12.03		*****	1.05	3.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	202				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1	.21		*****	22.9	56.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.008	.01		*****	1.8	2.7				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.85	1.52		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.46	.51		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2015	09/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 O O See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 P O See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 Q O See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 R O See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
71900 S O See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
74076 5 O Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.87	*****	8.26				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.54	16.46		*****	1.15	3.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	227				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.008	.03		*****	< 5	6.4				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.08	.15		*****	17.2	29.3				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.01	.02		*****	2.3	3.1				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.99	1.77		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	49				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.43	.6		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	8.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.62	*****	6.62				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.03	.03		*****	3.4	3.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	234				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0001	.0001		*****	18	18				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0001	.0001		*****	12	12				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0003	.0003		*****	39	39				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.02	.4		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	79				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
10/01/2015	10/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	63	65		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	11.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.47	*****	7.81				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.8	19.2		*****	.55	2.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	177				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.08		*****	< 5	6.3				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.06	.1		*****	6.3	8.2				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0097	.019		*****	1.2	1.9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.32	2.26		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	79				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.72	3.94		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .001				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	11.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.22	*****	7.89				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	2.6	5.5		*****	1.8	4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	196				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.02	.04		*****	16	27				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.01	.02		*****	9	14				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.24	.54		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2015	11/30/2015

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	66	95		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.84	*****	7.88				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	7.73	18.5		*****	.8	2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	152				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.17	.41		*****	16	44.2				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.07		*****	1.8	2.8				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.94	4.37		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	33				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	3.24	31.15		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	6.2				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.73	*****	7.73				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	3.86	15.43		*****	.5	2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	157				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.18		*****	17	23				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.04		*****	4	5				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.43	1.43		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2015	12/31/2015

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	112	880		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.8	*****	7.5				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	24.97	38.67		*****	1.75	2.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	172				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.07		*****	< 5	6.1				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.3	.45		*****	20	29.4				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.026	.04		*****	1.9	2.7				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.4	3.17		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	2	9.81		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	9.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.8	*****	7.73				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0		*****	< .1	< .1				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	187				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.03	.06		*****	11	20				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0003	.0009		*****	.01	.03				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.07	.11		*****	25	33				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.03	.05		*****	11	19				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.36	.7		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2016	01/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	77	118		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	14.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.95	*****	7.77				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	26.32	37.21		*****	2.35	3.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	173				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.18	.56		*****	15.1	49.8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.29	.42		*****	25.7	33.8				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.03	.07		*****	2.5	4.2				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.11	2.89		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	46				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	10.26	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	8.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.73	*****	8.01				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.04	11.11		*****	3.3	4.7				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	168				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.01	.03		*****	7	11				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0003	.0006		*****	.1	.2				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1	.21		*****	32	47				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.07	.16		*****	20	36				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.62	.95		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2016	02/29/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	246	753		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17.7				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	8				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	42.25	48.72		*****	3.35	3.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	197				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.23	.4		*****	18.8	31.1				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.24	.48		*****	19.2	40.5				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.02	.04		*****	1.5	3.3				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.61	4.82		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	70				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	15.29	34.59		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	12.4				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.17	*****	8.04				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	9.36	12.34		*****	2.2	3.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	172				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.02	.04		*****	5	8				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.13	.29		*****	32	79				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.07	.16		*****	16	36				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.75	1.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2016	03/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	442	1339		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	20.3				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.26				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	19.62	48.49		*****	1.8	4.2				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	190				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.06	.16		*****	5.8	15				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 1	< 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.95	3.03		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	79				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	19.06	27.71		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.6				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.18	*****	8.9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	4.8	5.48		*****	3.3	4.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	175				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.06	.1		*****	32	42				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.008	.012		*****	5	6				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.35	.56		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2016	04/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	1014	2153		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	13.8				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.26				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	11.0307	15.667		*****	1.15	1.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	198				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.219	.4573		*****	23	46.7				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0176	.0195		*****	< 1	< 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.63	1.92		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

Form Approved

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440

WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD

WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

LAKE CREEK

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	8.985	14.64		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
TYPED OR PRINTED					AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	19.47				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.18	*****	8.9				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.62	10.898		*****	3.5	4.8				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	195				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0509	.1042		*****	31	46				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0096	.0185		*****	6	8				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.26	.64		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2016	05/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	556	1474		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.5				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.92	*****	7.95				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	10.43	11.22		*****	1.3	1.6				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	73.8				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0287	.113		*****	4	16.1				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0018	.007		*****	.3	1				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1648	.3838		*****	22	54.7				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT				*****						
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0214	.0526		*****	3	7.5				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.48	1.72		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	46				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .01	< .01				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	3.475	5.99		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C

LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18.1				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.18	*****	7.93				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.4902	.4902		*****	3.4	4.4				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< 5	< 5				
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0		*****	< .3	< .3				
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.000025	.0001		*****	9	16				
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0004	.0017		*****	11	12				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.031	.223		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2016	06/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0		*****	< .001	< .001				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 9	NODI 9		*****	NODI 9	NODI 9				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	126.167	202		*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.4	deg C			
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.26	SU			
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	10.52	25.95	lb/d	*****	1.1	3	mg/L			
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	73.8	mg/L			
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	.0035	.1401	lb/d	*****	4	16.2	ug/L			
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	.0035	.0109	lb/d	*****	.4	1.26	ug/L			
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.1478	.2682	lb/d	*****	17	31	ug/L			
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

What is NODI?

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0418	.134	lb/d	*****	5	15.3	ug/L			
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.52	1.82	cfs	*****	*****	*****	*****		Daily	MEASRD
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	130	#/100mL			
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

What is NODI?

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L			
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.926	1.66	cfs	*****	*****	*****	*****			
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< .01	ug/L			
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

What is NODI?

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.8	deg C		Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.12	*****	8.12	SU		Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0	lb/d	*****	2.4	2.4	mg/L		Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	6.42	6.42	ug/L		Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	10.7	10.7	ug/L		Weekly	COMP24
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.009	.0034	cfs	*****	*****	*****	*****		Daily	MEASRD
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0	#/100mL		Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2016	07/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Once per 2 Weeks	GRAB
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	81.119	95.835	cfs	*****	*****	*****	*****		Daily	RCDFLO
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23.9	deg C		Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.88	*****	8.36	SU		Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.09	10.86	lb/d	*****	.75	1.6	mg/L		Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	175	mg/L		Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.131	.242	lb/d	*****	17	31	ug/L		Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		0/06/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0103	.0123	lb/d	*****	1	1.75	ug/L		Weekly	COMP24
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	1.27	1.43	cfs	*****	*****	*****	*****		Daily	MEASRD
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17	#/100mL		Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		0/06/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1	tox chronic		Quarterly	COMP24
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Once per 2 Weeks	GRAB
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.592	.74	cfs	*****	*****	*****	*****		Daily	RCDFLO
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		0/06/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0	ug/L		Quarterly	COMP24
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard	TELEPHONE	DATE
Corey Millard/ General Manager			(208)755-3569	0/06/2016
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<1.7 cfs, P>=1.7 to <3.8 cfs, Q>= 3.8 to <13.4 cfs, R>=13.4 to <23 cfs, S>=23 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	27.1	deg C		Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.12	*****	8.12	SU		Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.734	1.23	lb/d	*****	2.5	3.2	mg/L		Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	185	mg/L		Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0014	.0018	lb/d	*****	6	7.03	ug/L		Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0023	.0033	lb/d	*****	8.96	9.26	ug/L		Weekly	COMP24
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.025	.255	cfs	*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	94	#/100mL		Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2016	08/31/2016

DMR Mailing ZIP CODE: 83873
MAJOR (SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxicity, final conc toxicity units	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	< 1	tox chronic		Quarterly	COMP24
61406 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	tox chronic		Quarterly	COMP24
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Once per 2 Weeks	GRAB
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	65.5	67.171	cfs	*****	*****	*****	*****		Daily	RCD FLO
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCD FLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Corey Millard		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)755-3569		/9/29/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

* O<48 cfs, P>=48 to <109 cfs, Q>= 109 to <379 cfs, R>=379 to <649 cfs, S>=649 cfs

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	18.4	deg C		Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.07	*****	7.68	SU		Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	mg/L		Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	202 MO AVG	560 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	169	mg/L		Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	1.2 MO AVG	2.7 DAILY MX	lb/d	*****	87 MO AVG	195 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.012 MO AVG	.027 DAILY MX	lb/d	*****	.87 MO AVG	1.9 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0788	.1127	lb/d	*****	18	20.7	ug/L		Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.39 MO AVG	.81 DAILY MX	lb/d	*****	27 MO AVG	58 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578		0/13/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Chrome Vi was analyzed in August.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	.0055	.0162	lb/d	*****	1	2.9	ug/L		Weekly	COMP24
01119 O 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.29 DAILY MX	lb/d	*****	7.7 MO AVG	21 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 P 0 See Comments	PERMIT REQUIREMENT	.079 MO AVG	.21 DAILY MX	lb/d	*****	5.7 MO AVG	15 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.053 MO AVG	.14 DAILY MX	lb/d	*****	3.8 MO AVG	10 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	.061 MO AVG	.17 DAILY MX	lb/d	*****	4.4 MO AVG	12 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	.11 MO AVG	.32 DAILY MX	lb/d	*****	8.2 MO AVG	23 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.88	1.18	cfs	*****	*****	*****	*****		Daily	MEASRD
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	240	#/100mL		Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578		0/13/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Chrome Vi was analyzed in August.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR
(SUBR 01)
LAKE CREEK
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Once per 2 Weeks	GRAB
71900 O 0 See Comments	PERMIT REQUIREMENT	.00015 MO AVG	.0003 DAILY MX	lb/d	*****	.011 MO AVG	.022 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 P 0 See Comments	PERMIT REQUIREMENT	.00017 MO AVG	.00032 DAILY MX	lb/d	*****	.012 MO AVG	.023 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.00019 MO AVG	.00037 DAILY MX	lb/d	*****	.014 MO AVG	.027 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.00048 MO AVG	.00098 DAILY MX	lb/d	*****	.035 MO AVG	.071 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.00075 MO AVG	.0015 DAILY MX	lb/d	*****	.054 MO AVG	.11 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	.526	.58	cfs	*****	*****	*****	*****		Daily	RCDFLO
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO
Chromium, hexavalent tot recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI 9				
78247 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	ug/L		Quarterly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578		0/13/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Chrome Vi was analyzed in August.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	19.2	deg C		Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	deg C		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.25	*****	6.81	SU		Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.734	1.23	lb/d	*****	1.2	1.4	mg/L		Weekly	COMP24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	80 MO AVG	248 DAILY MX	lb/d	*****	20 MO AVG	30 DAILY MX	mg/L		Weekly	COMP24
Hardness, total [as CaCO3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	200	mg/L		Monthly	GRAB
00900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	mg/L		Monthly	GRAB
Zinc, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01094 1 0 Effluent Gross	PERMIT REQUIREMENT	.63 MO AVG	1.8 DAILY MX	lb/d	*****	85 MO AVG	237 DAILY MX	ug/L		Weekly	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Weekly	COMP24
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	.007 MO AVG	.019 DAILY MX	lb/d	*****	.91 MO AVG	2.6 DAILY MX	ug/L		Weekly	COMP24
Lead, total recoverable	SAMPLE MEASUREMENT	.0056	.0134	lb/d	*****	18	38	ug/L		Weekly	COMP24
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	.24 MO AVG	.66 DAILY MX	lb/d	*****	32 MO AVG	88 DAILY MX	ug/L		Weekly	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE		DATE
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578		0/13/2016
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

pH was below limit during the month but returned to within limits.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873
MAJOR
(SUBR 01)
SOUTH FORK COEUR D'ALENE RIVER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 O 0 See Comments	PERMIT REQUIREMENT	.42 MO AVG	.9 DAILY MX	lb/d	*****	56 MO AVG	120 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	.0037	.0071	lb/d	*****	10	12.5	ug/L		Weekly	COMP24
01119 P 0 See Comments	PERMIT REQUIREMENT	.48 MO AVG	.97 DAILY MX	lb/d	*****	64 MO AVG	130 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 Q 0 See Comments	PERMIT REQUIREMENT	.82 MO AVG	1.7 DAILY MX	lb/d	*****	110 MO AVG	230 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 R 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Copper, total recoverable	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
01119 S 0 See Comments	PERMIT REQUIREMENT	1.1 MO AVG	2.2 DAILY MX	lb/d	*****	150 MO AVG	300 DAILY MX	ug/L		Weekly	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.072	.145	cfs	*****	*****	*****	*****		Daily	MEASRD
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	MEASRD
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	23	#/100mL		Monthly	GRAB
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. INST MAX	#/100mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE		DATE	
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578		0/13/2016	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

pH was below limit during the month but returned to within limits.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME: U.S. SILVER CORP - IDAHO INC

ADDRESS: PO BOX 440
WALLACE, ID 83873

FACILITY: U.S. SILVER CORPORATION - IDAHO INC (COEUR AND C
LOCATION: 1041 LAKE GULCH ROAD
WALLACE, ID 83873

ATTN: COREY MILLARD, ENVIR SUPER

ID0000027	002-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
09/01/2016	09/30/2016

DMR Mailing ZIP CODE: 83873

MAJOR

(SUBR 01)

SOUTH FORK COEUR D'ALENE RIVER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 O 0 See Comments	PERMIT REQUIREMENT	.0009 MO AVG	.0018 DAILY MX	lb/d	*****	.12 MO AVG	.24 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	0	0	lb/d	*****	0	0	ug/L		Once per 2 Weeks	GRAB
71900 P 0 See Comments	PERMIT REQUIREMENT	.0013 MO AVG	.0026 DAILY MX	lb/d	*****	.18 MO AVG	.35 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 Q 0 See Comments	PERMIT REQUIREMENT	.0015 MO AVG	.0031 DAILY MX	lb/d	*****	.2 MO AVG	.41 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 R 0 See Comments	PERMIT REQUIREMENT	.0051 MO AVG	.011 DAILY MX	lb/d	*****	.68 MO AVG	1.4 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	NODI 1	NODI 1		*****	NODI 1	NODI 1				
71900 S 0 See Comments	PERMIT REQUIREMENT	.0075 MO AVG	.014 DAILY MX	lb/d	*****	1 MO AVG	2 DAILY MX	ug/L		Once per 2 Weeks	GRAB
Flow	SAMPLE MEASUREMENT	62.608	64.575	cfs	*****	*****	*****	*****		Daily	RCDFLO
74076 5 0 Upstream Monitoring	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	cfs	*****	*****	*****	*****		Daily	RCDFLO

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Matthew Drews		TELEPHONE	DATE
Corey Millard/ General Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)682-5578	0/13/2016
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

pH was below limit during the month but returned to within limits.